

CHECKLIST

WET WORK JOB SITE INSPECTION

Presented by Plan Insurance Brokers

Wet Work Job Site Inspection Questions	YES	NO
Has all necessary equipment required to complete the wet work been provided? Is this equipment adequately maintained and in good condition?	<input type="checkbox"/>	<input type="checkbox"/>
Are all pressure-testing devices or rigs suitable for the current construction site conditions (eg temperature, pressure and flow rates)?	<input type="checkbox"/>	<input type="checkbox"/>
Is there a well-documented plan in place that explains what to do if a leak or accidental water discharge occurs? Has this plan been communicated in routine construction site meetings?	<input type="checkbox"/>	<input type="checkbox"/>
Are the locations of all shut-off valves well-known and accessible? Are these valves properly labelled for easy identification?	<input type="checkbox"/>	<input type="checkbox"/>
Are all pipe diagrams readily available?	<input type="checkbox"/>	<input type="checkbox"/>
Has any piping been drained before the start of the wet work?	<input type="checkbox"/>	<input type="checkbox"/>
Is there an easily accessible spill response cart at the construction site?	<input type="checkbox"/>	<input type="checkbox"/>
Are there any floor openings or cracks through which a leaking fluid could enter and damage areas below? If so, can these openings or cracks be adequately blocked and protected?	<input type="checkbox"/>	<input type="checkbox"/>
Are there adequate controls in place to protect any sensitive equipment—such as electrical tools or devices—from water damage?	<input type="checkbox"/>	<input type="checkbox"/>
Are all drains at the construction site—both in the floors and any sinks—fully functional and clean?	<input type="checkbox"/>	<input type="checkbox"/>
Is any work being performed on the roof? If so, are all roof drains and scuppers completely operational and free of debris? Do any roof drains or downspouts permit water to run back into the building?	<input type="checkbox"/>	<input type="checkbox"/>
Has an individual (or group of individuals) at the construction site been designated as the dedicated 'water watch' (a person or group of people responsible for helping inspect the job site during and after the wet work to ensure any leaking or water damage has not occurred)? Is this individual (or group of individuals) fully competent, trained and qualified for such a responsibility?	<input type="checkbox"/>	<input type="checkbox"/>